Quick start guide DDA kit

Mini Monitor for use with Telecare Communicators



Connecting to the NEAT LINK

Any questions? Call us on +353 (0)1 247 9007


This quick start guide explains the process of connecting Silent Alert equipment to certain Telecare communicators for DDA compliance.

Whilst a wireless smoke alarm unit will alert the call centre, a deaf or hard of hearing person may miss the alarm and be unaware of the danger. By using a Silent Alert DDA kit, the user will be alerted immediately and can respond or react as necessary. This ensures deaf and hard of hearing people can be made aware of integrated Telecare smoke alarms whilst reducing false alarm call outs.


The user will also be able to expand on the benefits of the Telecare system by having access to doorbell, telephone, baby alarm and door entry systems whilst still having the security of a remotely monitored smoke alarm and emergency pendant.

This information is not intended to replace the manufacturers user instructions. The assistance of the Telecare providers technicians will be required to enable correct output.

Standard operation




1. Install a 9 volt PP3 alkaline or lithium battery making sure to observe the correct polarity.




When a battery is first fitted the indicator light will flash red then green a few times.

The light will then flash green several times to show the battery voltage.

9 flashes = 9Volts in the battery.



To repeat the battery check remove the battery, press the test button then re-insert the battery to start the sequence again.




3. The monitor will now trigger when the telecare unit activates its external output.

A fire signal will be sent to the Pager or SignWave when the Telecare relay activates.



It is possible for the monitor to light up different keys on the Pager or SignWave.



For more information on configuring the Mini Monitor please refer to the dedicated quick guide supplied with each unit. Alternatively, you can download the information from out website at www.silentalert.ie.


Quick start guide DDA kit Connecting Silent Alert to the NEAT LINK



Any questions? Call us on +353 (0)1 247 9007


Connecting to the NEAT LINK

Please refer to the NEAT LINK installation instructions before connecting our unit to the system. The Telecare technician should refer to pages 7 & 9 of the installation and programming guide regarding connecting an alarm transmitter to the LINK.




To trigger the Silent Alert System the NEAT LINK will need to be configured to output a 3 second short when a smoke alarm is triggered.


To configure the unit the lid must be removed by removing the 4 mounting screws.



3.




Configure the unit to only trigger on Pre Programmed alarms by fitting the jumper to position one. 4.



Ensure no jumpers are set on positions 4, 5 or 6.

This will set the unit to pulse mode whereby the output relay will be closed for 3 seconds when an alarm is received.



Ensure the LINK is switched off.

Press and hold the button inside of the LINK while switching LINK on. 6.



Keep holding the button and wait until the LED inside LINK flashes once to configure the smoke alarm to channel one of the LINK.


Release the button. This will put the LINK into programming mode.

7.



Activate the NEAT Smoke alarm transmitter.

The LED inside the LINK will flash once to indicate the alarm code is stored.



Connect the LINK's power supply and connect the Silent Alert monitor to the LINK's output.

When the NEAT smoke alarm activates the Silent Alert Pager or SignWave will alert the deaf user. 9.

For information on configuring the Silent Alert monitor please refer to the advance settings overleaf.

WARNING

Do not connect the equipment in any way other than illustrated. Silent Alert International accepts no responsibility for damage caused by incorrect installation.